

High Performance and Efficiency

- 750 or 1250 Gallons Per Day
- 96%+ Rejection of Total Dissolved Solids
- 1 to 2.60 Waste to Product Water Ratio



AXEON HYDRO RO-SERIES

High Efficiency Hyperfiltration System

AXEONWATER.COM



SPECIFICATIONS

Flow Rate ^C (gpd–750 System / 1250 System)	750 / 1250
Rejection Rate (%)	96+
Efficiency Rate	See Chart Below
Sediment Filter Change (Months)	3 - 6
Carbon Filter Change (Months)	3 - 6
HyperFilter Change (Months)	6 - 12
Voltage	100 - 120V 50 / 60 HZ
Dimensions L x W x H (in)	16 x 9 x 27
Dry Weight (lbs–750 System / 1250 System)	20.5 / 27.4



OPERATING LIMITS^A

AXEON [®] HYDRO – 750 Expected Flow Rates					
Inlet Pressure (psi)	Gallons Per Day (gpd)	Gallons Per Hour (gph)	Product Water to Waste Ratio		Recovery Rate %
40	375	15.63	1.10	1	52%
50	450	18.75	1.60	1	61%
60	550	22.92	1.95	1	66%
70	650	27.08	2.25	1	69%
80	750	31.25	2.50	1	71%
AXEON HYDRO – 1250 Expected Flow Rates					
100	1250	52.08	2.60	1	72.5%

gpd = gallons per day, gph = gallons per hour

Design Temperature (°F / °C)	77 / 25	Minimum Feed Pressure (psi / bar) ^B	40 / 2.76
Maximum Feed Temperature (°F / °C)	85 / 29	Maximum Feed Silt Density Index (SDI)	< 3
Minimum Feed Temperature (°F / °C)	40 / 4	Maximum Turbidity (NTU)	1
Maximum Ambient Temperature (°F / °C)	120 / 49	Maximum Free Chlorine (ppm)	< 1
Minimum Ambient Temperature (°F / °C)	40 / 4	Maximum TDS (ppm)	1000
Maximum Feed Pressure (psi / bar) ^B	100 / 6.89	Maximum Hardness (gpg)	< 10

- A. If any of the feed water parameters are not within the limits given, consult your local dealer or distributor for assistance.
- B. System operating pressure is based on 40 psi feed pressure, minimum concentrate flow as stated, and an average of 375 GPD flow per membrane at 77 °F / 25 °C.
- C. Low temperatures and feedwater quality, such as high TDS levels, will significantly affect the system's production capabilities and performance. Use on microbiologically safe water only and follow all state and federal plumbing and electrical codes.

Warranty Evaluation Test Conditions: Permeate flow rates and salt rejection based on the following test conditions – 550 ppm, filtered and dechlorinated municipal tap water, 77 °F / 25 °C, 15% recovery, 7.0 pH and the specified operating pressure for membrane element type. Data taken after 60 minutes of operation.



Scan this QR code to visit us at [AXEONwater.com](https://www.AXEONwater.com)