



System Part #: 01-10/35

Materials of Construction

Filter Media	Carbon
Housing	polypropylene



IL-35 has been independently tested and certified by NSF International against NSF/ANSI Std. 42
 Do not use with water that is microbiologically unsafe or of unknown quality
 *Independently tested to remove or reduce

Cartridge Specifications and Performance Data

Model	Maximum Dimensions	Micron Rating	Initial ΔP (psi) at Flow Rate (gpm)*	Chlorine Taste & Odor Reduction at Flow rate (gpm)*	Temperature Rating
IL-35	3" x 3" x 12"	1	5 psi @ 2 gpm	3,000 gallons @ 2 gpm 11,356 + liters @ 7.57 Lpm	40°F to 100°F

Test Parameters

Substance	Influent Challenge Concentration	Reduction Requirement	Maximum Permissible Product Water Concentration mg/L	Actual Reduction Percentage
Chlorine	2.0 mg/L ± 10%	≥ 50%	1.0	99%

3980 Lakefield Court • Suwanee, GA 30024 USA

P: 678-475-0799 • 800-635-4017

F: 678-475-9126 • 800-811-7682

www.selectoinc.com

Ver. I, Aug 2010 JN