



A Watts Water Technologies Company

REVERSE OSMOSIS

INSTALLATION AND OPERATION MANUAL

Model R4X40



IMPORTANT

Please read the entire manual before proceeding with the installation and startup:

- Do not use where the water is microbiologically unsafe.
- Always turn off the unit, shut off the feed water, and disconnect the electrical power when working on the unit.
- Never allow the pump to run dry.
- Never start the pump with the reject valve closed.
- Never allow the unit to freeze or operate with a feed water temperature above 100°F.

NOTES

Changes in operating variables are beyond the control of the system manufacture. The end user is responsible for the safe operation of this equipment. The suitability of the product water for any specific application is the responsibility of the end user.

Successful long-term performance of an RO system depends on proper operation and maintenance of the system. This includes the initial system startup and operational startups and shutdowns. Prevention of fouling or scaling of the membranes is not only a matter of system design, but also a matter of proper operation. Record keeping and data normalization are required in order to know the actual system performance and to enable corrective measures when necessary. Complete and accurate records are also required in case of a system performance warranty claim.

Changes in the operating parameters of an RO system can be caused by changes in the feed water or can be a sign of trouble. Maintaining an operation and maintenance log is crucial in diagnosing and preventing system problems. For your reference, a typical log sheet is included in this manual.

TABLE OF CONTENTS

I. Introduction

- A. Specifications
- B. RO Overview
- C. Pre-treatment

II. Controls, Indicators, and Components

III. Operation

- A. Installation
- B. Plumbing Connections
- C. Electrical
- D. Startup
- E. Control Function
- F. Operation and Maintenance Log
- G. Troubleshooting

IV. Replacement Parts List

V. Membrane Replacement

VI. Appendix

- Temperature Correction Factors

I. INTRODUCTION

The separation of dissolved solids and water using RO membranes is a pressure driven temperature dependent process. The membrane material is designed to be as permeable to water as possible, while maintaining the ability to reject dissolved solids.

The main system design parameters require the following:

- Internal flows across the membrane surface must be high enough to prevent settling of fine suspended solids on the membrane surface.
- The concentration of each dissolved ionic species must not exceed the limits of solubility anywhere in the system.
- Pre-treatment must be sufficient to eliminate chemicals that would attack the membrane materials.

A. SPECIFICATIONS


	R4X40-1	R4X40-2	R4X40-3
Maximum Productivity (gallons per day)	2200	4400	6600
Quality (average membrane rejection)	98 %		
Recovery (user adjustable)	15 - 75 %	25 – 75%	32 - 75 %
Membrane Size	4" x 40"		
Number Of Membranes	1	2	3
Prefilter (system ships with one 5 micron cartridge)	20"		
Feed Water Connection	3/4" NPTF		
Product Water Connection (tubing OD)	5/8"		
Reject Water Connection (tubing OD)	5/8"		
Feed Water Required (maximum)	10 gpm	12 gpm	14 gpm
Feed Water Pressure (minimum)	10 psi		
Drain Required (maximum)	10 gpm	12 gpm	14 gpm
Electrical Requirement (60 Hz)	120 V - 15 amps	120 V - 20 amps	240 V - 12 amps
Motor Horse Power	3/4	1	1 1/2
Dimensions W x D x H (approximate inches)	20 x 20 x 50		20 x 26 x 50
Shipping Weight (estimated pounds)	120	150	180

Notes:

- Maximum production based on a feed water of 77°F, SDI < 1, 1000 ppm TDS, and pH 7. Individual membrane productivity may vary (\pm 15%). May be operated on other feed waters with reduced capacity.
- Percent Rejection is based on membrane manufactures specifications; overall system percent rejection may be less.

B. RO OVERVIEW

Reverse osmosis systems utilize semipermeable membrane elements to separate the feed water into two streams. The pressurized feed water is separated into purified (product) water and concentrate (reject) water. The impurities contained in the feed water are carried to drain by the reject water. It is critical to maintain adequate reject flow in order to prevent membrane scaling and/or fouling.



C. PRETREATMENT

The RO feed water must be pretreated in order to prevent membrane damage and/or fouling. Proper pretreatment is essential for reliable operation of any RO system.

Pretreatment requirements vary depending on the nature of the feed water. Pretreatment equipment is sold separately. The most common forms of pretreatment are described below.

Media Filter - Used to remove large suspended solids (sediment) from the feed water. Backwashing the media removes the trapped particles. Backwash can be initiated by time or differential pressure.

Water Softener - Used to remove calcium and magnesium from the feed water in order to prevent hardness scaling. The potential for hardness scaling is predicted by the Langelier Saturation Index (LSI). The LSI should be zero or negative throughout the unit unless approved anti-scalants are used. Softening is the preferred method of controlling hardness scale.

Carbon Filter - Used to remove chlorine and organics from the feed water. Free chlorine will cause rapid irreversible damage to the membranes.

The residual free chlorine present in most municipal water supplies will damage the thin film composite structure of the membranes used in this unit. Carbon filtration or sodium bisulfite injection should be used to completely remove the free chlorine residual.

Chemical Injection - Typically used to feed antiscalant, coagulant, or bisulfite into the feed water or to adjust the feed water pH.

Prefilter Cartridge - Used to remove smaller suspended solids and trap any particles that may be generated by the other pretreatment. The cartridge(s) should be replaced when the pressure drop across the housing increases 5 - 10 psig over the clean cartridge pressure drop.

The effect of suspended solids is measured by the silt density index (SDI) test. An SDI of five (5) or less is specified by most membrane manufacturers and three (3) or less is recommended.

Iron & Manganese - These foulants should be removed to less than 0.1 ppm. Special media filters and/or chemical treatment is commonly used.

pH - The pH is often lowered to reduce the scaling potential. If the feed water has zero hardness, the pH can be raised to eliminate CO₂.

Silica: Reported on the analysis as SiO₂. Silica forms a coating on membrane surfaces when the concentration exceeds its solubility. Additionally, the solubility is highly pH and temperature dependent. Silica fouling can be prevented with chemical injection and/or reduction in recovery.

II. CONTROLS, INDICATORS, and COMPONENTS (see figure 1)

- A. On / Off Switch – Turns the unit on and off.
- B. Power, low-pressure, tank level, and pretreatment indicators.
- C. Reject Control Valve - Controls the amount of reject flow.
- D. Reject Recycle Control Valve – Controls the amount of recycle flow.
- E. Prefilter Outlet Pressure Gauge - Indicate the outlet pressures of the prefilter.
- F. Pump Discharge Pressure Gauge - Indicates the membrane feed pressure.
- G. Reject Flow Meter - Indicates the reject flow rate in gallons per hour (gph).
- H. Product Flow Meter - Indicates the product flow rate in gallons per hour (gph).
- I. Prefilter Housing - Contains the RO prefilter.
- J. RO Feed Pump - Pressurizes the RO feed water.
- K. RO Membrane Housing(s) - Contains the RO membrane(s).
- L. Water Quality Meter – Indicates the quality of the feed and product water in parts per million of total dissolved solids (PPM – TDS).
- M. Feed Water Inlet.




Figure 1

Controller Connections




Figure 2

III. OPERATION

A. INSTALLATION

1. Proper pretreatment must be determined and installed prior to the RO system.
2. The water supply and pretreatment equipment should be sufficient to provide a minimum of 10-psig at the maximum feed flow.
3. An electrical receptacle with a ground fault interrupt (GFI) is highly recommended.
4. Responsibility for meeting local electrical and plumbing codes lies with the owner / operator.
5. Install indoors in an area protected from freezing. Space allowances for the removal of the membranes from the pressure vessels should be provided.
6. Verify that a prefilter cartridge is installed in the housing. (see figure #1, item I).

B. PLUMBING CONNECTIONS

Note: It is the responsibility of the end user to ensure that the installation is done according to local codes and regulations.

1. Connect the pretreated feed water line to the prefilter inlet (Figure # 1 item M). A feed water shutoff valve should be located within 10 feet of the system.
2. Temporarily connect the product water outlet to a drain. The product outlet is located behind the panel at the top of the product flow meter. The product water line should never be restricted. Membrane and/or system damage may occur if the product line is blocked.
3. Connect the reject water outlet to a drain. The reject outlet is located behind the panel at the top of the reject flow meter. The reject drain line should never be restricted. Membrane and/or system damage may occur if the reject drain line is blocked. An air gap must be located between the end of the drain line and the drain. The use of a standpipe or other open drain satisfies most state and local codes and allows for visual inspection and sampling.

C. ELECTRICAL

Note: It is the responsibility of the end user to ensure that the installation is done according to local codes and regulations.

1. Make sure the on / off switch is in the off position (Figure # 1 item A).
2. Plug the unit into a 115 volt 3 prong outlet. Note – The R4X40-2 requires a 20 amp outlet. Systems configured for 230 volts do not come with a plug.
3. If a tank level switch and/or pretreatment interlock is used, remove the jumper(s) from the terminals on the controller and install the switch leads into the terminals (see figure #2). The tank level and pretreatment interlock switches should be closed for the RO system to run. When the circuit is open the RO system turns off and the front panel indicator turns on.

D. STARTUP

1. Verify that the pretreatment equipment is installed and working properly. Verify that no free chlorine is present in the feed water.
2. Verify that the on / off switch is in the off position.
3. Verify that a filter cartridge is installed in the prefilter housing.
4. Open the reject control valve completely (Figure # 1 item C) by turning it counterclockwise.
5. Close the reject recycle control valve (Figure # 1 item D) completely by turning it clockwise.
6. Open the feed water shutoff valve installed in step III-B-1 above.
7. Move the controller on/off switch to the on position.
8. Allow the unit to run for 15 – 30 minutes to flush the preservative from the membrane(s).
9. Adjust the reject control valves (Figure # 1 items C & D) until the desired flows are achieved. Closing the reject valve increases the product flow and decreases the reject flow. Opening the reject recycle valve decreases both the reject and product flow. See the flow rate guidelines and temperature correction table in the appendix to determine the flow rates for different operating temperatures.
10. Allow the product water to flow to drain for 30 minutes.
11. Turn off the system and connect the product line to the point of use. The product water line should never be restricted. Membrane and/or system damage may occur if the product line is blocked.
12. Restart the system and record the initial operating data using the log sheet.

E. CONTROL FUNCTION

1. When the on / off switch is in the on position, the inlet valve opens and the pump runs. There is a five second delay between the opening of the inlet valve and the starting of the pump. If the water pressure feeding the pump drops below five psi for more than five seconds, the pump will turn off and the low pressure indicator on the front of the controller will turn on. The controller will automatically reset after 30 minutes and the pump will turn back on. Note: The default low pressure reset time is 30 minutes. The time delay can be changed to five minutes using the low pressure reset switch located inside the controller (figure #2) . Cycle the on / off switch to manually reset a low-pressure shutdown.
2. The controller also monitors the low tank level and pretreatment interlock switches if they are installed. When the tank level switch opens for five continuous seconds the pump turns off and the inlet valve closes. When the tank level switch closes the inlet valve opens and the pump turns on. If the pretreatment interlock switch opens the pump turns off with no delay and the inlet valve closes. When the pretreatment interlock switch closes the inlet valve opens and the pump starts.
3. Quality Meter – The quality meter measures the feed water and product water total dissolved solids (TDS) in parts per million (PPM). The lower the TDS the more pure the water is. To check the TDS press the power button, then press either the IN or OUT button. The IN button checks the feed water TDS and the OUT button checks the

product water TDS. The meter will automatically turn it self off after a few seconds. The quality meter is powered by two AAA batteries. To replace the batteries, lift the meter out of the bracket and remove the back cover.

G. TROUBLESHOOTING

RO MEMBRANE TROUBLE SHOOTING GUIDE						
SYMPTOMS			Location	Possible Causes	Verification	Corrective Action
Salt Passage	Permeate Flow	Pressure Drop				
Normal to increased	Decreased	Normal to increased	Predominantly first stage	Metal oxide	Analysis of metal ions in cleaning solution.	Improved pretreatment to remove metals. Cleaning with acid cleaners.
Normal to increased	Decreased	Normal to increased	Predominantly first stage	Colloidal fouling	SDI measurement of feed/ X-ray diffraction analysis of cleaning sol. residue.	Optimize pretreatment system for colloid removal. Clean with high pH, anionic detergent formulation.
Increased	Decreased	Increased	Predominantly last stage	Scaling (CaSO ₄ , CaSO ₃ , BaSO ₄ , SiO ₂)	Analysis of metal ions in cleaning sol. Check LSI of reject. Calculate maximum solubility for CaSO ₄ , BaSO ₄ , SiO ₂ in reject analysis.	Increase acid addition and scale inhibitor for CaSO ₃ and CaSO ₄ . Reduce recovery. Clean with an acid formulation for CaCO ₃ , CaSO ₄ and BaSO ₄ .
Normal to moderate increase	Decreased	Normal to moderate increase	Can occur in any stage	Biological fouling	Bacteria count in permeate and reject. Slime in pipes and vessels.	Shock dosage of sodium bisulfite. Continuous feed of low conc. bisulfite at reduced pH. Peracetic acid sterilization. Clean with alkaline anionic surfactant. Chlorine dosage upstream with dechlorination. Replace cartridge filters.
Decreased or moderately increased	Decreased	Normal	All stages	Organic fouling	Destructive testing, e.g. IR reflection analysis.	Optimization of pretreatment system (e.g. coagulation process.) Resin/activated carbon treatment. Clean with high pH detergent.
Increased	Increased	Decreased	Most severe in the first stage	Chlorine oxidant attack	Chlorine analysis of feed. Destructive element test.	Check chlorine feed equipment and dechlorination equipment.
Increased	Increased	Decreased	Most severe in the first stage	Abrasion of membrane by crystalline material	Microscopic solids analysis of feed. Destructive element test.	Improved pretreatment. Check all filters for media leakage.
Increased	Normal to increased	Decreased	At random	O-ring leaks, End or side seal glue leaks.	Probe test. Vacuum test. Colloidal material passage.	Replace O-rings. Repair or replace elements.
Increased	Normal to low	Decreased	All stages	Conversion too high.	Check flows and pressures against design guidelines	Reduce conversion rate. Calibrate sensors. Increase analysis and data collection.

RO SYSTEM TROUBLE SHOOTING

PROBLEM	REMEDY
General	
High Product Water TDS	
Membrane frozen, high temp, or backpressure.	Replace membrane.
Membrane attack by chlorine	Carbon pre-filter may be exhausted. Replace filter and membrane.
Product seal on end cap.	Determine if seal or o-ring is bad. Replace as needed.
No Product Water or Not Enough Product Water	
Feed water shut off.	Turn on feed water.
Low feed pressure. Feed pressure must be at least 10 psi.	Consider booster pump.
Pre-filter cartridge clogged.	Replace pre-filter cartridge.
Membrane fouled.	Determine and correct cause; replace or clean membrane.
Product check valve stuck.	Clean or replace check valve.
Low pump discharge pressure	Adjust reject valve or replace pump
Low feed water temperature	Increase membrane feed pressure or heat the feed water.

IV. REPLACEMENT PARTS LIST

A list of common replacement parts is provided below. Contact your dealer for replacement parts assistance.

Part Number	Description
FPMB5-20	Prefilter, 5 micron, melt blown
W-4040-LE	RO membrane, low energy
R2451	Prefilter pressure gauge 0 – 100 psi
PG20B25	Pump discharge pressure gauge 0 – 300 psi
R4507	Product flow meter 0.5 – 5 gpm
R5316	Reject flow meter with valve 0.5 – 5 gpm
WDM-2	Water quality meter
R6316-HPS7D	Pump & motor 0.75 HP for R4X40-1
R6316-HPS7E	Pump & motor 1.0 HP for R4X40-2
R6316-HPS10F	Pump & motor 1.5 HP for R4X40-3
R23-1075	Controller with on/off switch
R23-PS32	Low pressure switch, ¼” MPT
T1100	Recycle needle valve PVC
K8012-24	Inlet solenoid valve, ¾”, 24 volt coil
R96-R4040A300E	Pressure vessel with end caps, 300 psi, FRP

V. MEMBRANE REPLACEMENT

1. Turn off the system and close the feed water shutoff valve.
2. Unplug the unit.
3. Disconnect the tubing from the top of the membrane housing(s).
4. Loosen the clamps and remove the top end cap(s).
5. Remove the old membrane(s) by pulling them up and out of the housings. You may need to grab the old membrane with a pair of pliers.
6. Install the new membrane(s) in the housing(s) and replace the end caps. The new membranes should be installed in the same orientation as the old membranes.
Note: It is very important that the brine seal does not flip up or roll when installing the membrane brine seal first. Use plenty of glycerin lubricant and use a gentle twisting / rocking motion as you slide the membrane in. If you are unable to install the membrane brine seal first without rolling the seal then lay the unit over, remove the bottom end cap, and install the membrane brine seal last.
7. Reconnect the tubing to the top of the membrane housing(s).
8. Follow the start up procedure in section III-D.

VI. APPENDIX

The following tables are intended as a guide to determining the flow rates for the R4X40 series RO systems. All flows are in gallons per minute (GPM) with 77°F feed water.

Nominal flows for systems operating at 50% recovery with a feed water SDI < 1.

	R4X40-1	R4X40-2	R4X40-3
Product GPM	1.5	3.0	4.5
Reject GPM	1.5	3.0	4.5

Nominal flows for systems operating at 50% recovery with a feed water SDI < 3.

	R4X40-1	R4X40-2	R4X40-3
Product GPM	1.25	2.5	3.75
Reject GPM	1.25	2.5	3.75

Nominal flows for systems operating at 50% recovery with a feed water SDI 3 to < 5.

	R4X40-1	R4X40-2	R4X40-3
Product GPM	1	2	3
Reject GPM	1	2	3

Temperature Correction Factors

Deg C	Deg F	Correction Factor
25	77	1.00
24	75.2	0.97
23	73.4	0.94
22	71.6	0.92
21	69.8	0.89
20	68	0.86
19	66.2	0.84
18	64.4	0.81
17	62.6	0.79
16	60.8	0.77
15	59	0.74
14	57.2	0.72
13	55.4	0.70
12	53.6	0.68
11	51.8	0.66
10	50	0.64
9	48.2	0.62
8	46.4	0.61
7	44.6	0.59
6	42.8	0.57
5	41	0.55

Multiply the nominal product flow at 25° C by the temperature correction factor to determine the flow at various other temperatures.